

Design iGuzzini iGuzzini

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	73	70	67	65	69	66	66	64	78
1.0	76	73	71	69	72	70	70	67	83
1.5	80	78	76	74	77	75	74	72	89
2.0	83	81	79	78	80	78	78	75	93
2.5	84	83	82	81	82	81	80	78	96
3.0	85	84	83	83	83	82	81	79	98
4.0	86	85	85	84	84	84	82	81	99
5.0	87	86	86	86	85	84	83	81	100

UGR diagram

Corrected UGR values (at 1100 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceiling/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim											
x	y										
2H	2H	-7.8	-7.3	-7.5	-7.1	-6.8	-7.8	-7.3	-7.5	-7.1	-6.8
	3H	-7.9	-7.5	-7.6	-7.2	-6.9	-7.9	-7.5	-7.6	-7.2	-6.9
	4H	-8.0	-7.6	-7.7	-7.3	-7.0	-8.0	-7.6	-7.7	-7.3	-7.0
	6H	-8.1	-7.7	-7.7	-7.4	-7.0	-8.1	-7.7	-7.7	-7.4	-7.1
	8H	-8.1	-7.7	-7.8	-7.4	-7.1	-8.1	-7.7	-7.8	-7.4	-7.1
	12H	-8.1	-7.8	-7.8	-7.4	-7.1	-8.2	-7.8	-7.8	-7.5	-7.1
4H	2H	-8.0	-7.6	-7.7	-7.3	-7.0	-8.0	-7.6	-7.7	-7.3	-7.0
	3H	-8.2	-7.8	-7.8	-7.5	-7.1	-8.2	-7.8	-7.8	-7.4	-7.1
	4H	-8.2	-7.9	-7.9	-7.6	-7.2	-8.2	-7.9	-7.9	-7.6	-7.2
	6H	-8.3	-8.0	-7.9	-7.6	-7.2	-8.3	-8.0	-7.9	-7.6	-7.2
	8H	-8.4	-8.1	-7.9	-7.7	-7.2	-8.4	-8.1	-7.9	-7.7	-7.3
	12H	-8.4	-8.2	-7.9	-7.7	-7.3	-8.4	-8.2	-8.0	-7.8	-7.3
8H	4H	-8.4	-8.1	-7.9	-7.7	-7.3	-8.4	-8.1	-7.9	-7.7	-7.2
	6H	-8.5	-8.2	-8.0	-7.8	-7.3	-8.4	-8.2	-8.0	-7.8	-7.3
	8H	-8.5	-8.3	-8.0	-7.8	-7.3	-8.5	-8.3	-8.0	-7.8	-7.3
	12H	-8.5	-8.3	-8.0	-7.9	-7.3	-8.5	-8.4	-8.0	-7.9	-7.4
12H	4H	-8.4	-8.2	-8.0	-7.8	-7.3	-8.4	-8.2	-7.9	-7.7	-7.3
	6H	-8.5	-8.3	-8.0	-7.9	-7.4	-8.5	-8.3	-8.0	-7.8	-7.3
	8H	-8.5	-8.4	-8.0	-7.9	-7.4	-8.5	-8.3	-8.0	-7.9	-7.3
Variations with the observer position at spacing:											
S =		1.0H	6.7 / -11.6				6.7 / -11.6				
		1.5H	9.6 / -12.2				9.6 / -12.2				
		2.0H	11.5 / -12.6				11.5 / -12.6				