





Polar



Coefficientes de uso

R	77	75	73	71	55	53	33	00	DRR
K0.8	44	38	35	32	36	33	31	26	54
1.0	48	43	39	36	40	37	34	29	61
1.5	54	49	46	44	46	43	40	34	72
2.0	57	53	51	48	49	47	44	38	79
2.5	59	56	54	52	52	50	46	40	83
3.0	60	58	56	54	53	52	48	41	86
4.0	62	60	58	57	55	54	50	43	90
5.0	62	61	60	58	56	55	51	44	92

Curva límite de luminancia



# Diagrama UGR

Corrected UGR values (at 5200 lm bare lamp luminous flux)											
Reflect.: ceiling/cav walls work pl. Room dim x y		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
		viewed crosswise					viewed endwise				
2H	2H	13.8	14.5	14.5	15.2	16.0	15.0	15.7	15.7	16.4	17.2
	3H	14.3	15.0	15.1	15.7	16.5	15.1	15.8	15.8	16.5	17.3
	4H	14.5	15.1	15.3	15.8	16.7	15.1	15.7	15.8	16.4	17.3
	6H	14.6	15.2	15.4	15.9	16.8	15.0	15.6	15.8	16.3	17.2
	8H	14.7	15.2	15.4	15.9	16.8	15.0	15.5	15.8	16.3	17.2
	12H	14.7	15.2	15.4	15.9	16.8	15.0	15.4	15.7	16.2	17.1
4H	2H	14.1	14.7	14.8	15.4	16.3	15.7	16.3	16.4	17.0	17.8
	3H	14.8	15.3	15.5	16.0	16.9	15.9	16.4	16.7	17.2	18.1
	4H	15.0	15.5	15.8	16.2	17.2	16.0	16.4	16.8	17.2	18.2
	6H	15.2	15.6	16.0	16.4	17.4	16.0	16.4	16.8	17.2	18.2
	8H	15.3	15.6	16.1	16.4	17.4	16.0	16.3	16.8	17.2	18.1
	12H	15.3	15.6	16.1	16.4	17.4	16.0	16.3	16.8	17.1	18.1
8H	4H	15.1	15.4	15.9	16.2	17.2	16.2	16.6	17.1	17.4	18.4
	6H	15.4	15.7	16.2	16.5	17.5	16.3	16.6	17.2	17.4	18.5
	8H	15.5	15.7	16.3	16.6	17.6	16.4	16.6	17.2	17.4	18.5
	12H	15.6	15.8	16.4	16.6	17.7	16.4	16.6	17.2	17.4	18.5
12H	4H	15.1	15.4	15.9	16.2	17.2	16.3	16.6	17.1	17.4	18.4
	6H	15.4	15.6	16.2	16.5	17.5	16.4	16.6	17.2	17.5	18.5
	8H	15.5	15.7	16.4	16.6	17.6	16.4	16.6	17.3	17.5	18.5
Variations with the observer position at spacing:											
S =		1.0H	0.5 / -0.5		0.3 / -0.5						
		1.5H	0.6 / -1.2		0.8 / -1.2						
		2.0H	1.2 / -1.9		1.8 / -1.8						