



QM03: Ø887mm - warm white - microprismado - DALI



Se conforma con EN60598-1 y regulaciones pertinentes



Coefficientes de uso

R	77	75	73	71	55	53	33	00	DRR
K0.8	48	42	37	34	41	37	36	32	46
1.0	53	47	42	39	46	42	41	37	54
1.5	60	55	51	48	53	50	49	45	66
2.0	63	59	56	54	58	55	55	51	74
2.5	66	62	60	57	61	59	58	54	79
3.0	67	65	62	60	63	61	60	57	82
4.0	69	67	65	63	65	64	63	60	86
5.0	70	68	67	65	67	65	64	61	89

Curva límite de luminancia




Diagrama UGR

Corrected UGR values (at 10100 lm bare lamp luminous flux)											
Reflect.: ceiling/cav walls work pl. Room dim x y		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
		viewed crosswise					viewed endwise				
2H	2H	16.2	17.3	16.5	17.5	17.8	16.2	17.3	16.5	17.5	17.8
	3H	17.0	18.0	17.4	18.3	18.6	16.5	17.5	16.8	17.8	18.1
	4H	17.4	18.3	17.7	18.6	18.9	16.6	17.5	16.9	17.8	18.1
	6H	17.7	18.6	18.1	18.9	19.2	16.6	17.4	17.0	17.7	18.1
	8H	17.9	18.6	18.2	19.0	19.3	16.6	17.4	17.0	17.7	18.1
	12H	17.9	18.7	18.3	19.0	19.4	16.5	17.3	16.9	17.7	18.0
4H	2H	16.6	17.5	16.9	17.8	18.1	17.4	18.3	17.7	18.6	18.9
	3H	17.6	18.4	18.0	18.7	19.1	17.9	18.6	18.3	19.0	19.4
	4H	18.1	18.7	18.5	19.1	19.5	18.1	18.8	18.5	19.1	19.5
	6H	18.5	19.1	19.0	19.5	19.9	18.2	18.8	18.7	19.2	19.7
	8H	18.7	19.2	19.1	19.7	20.1	18.3	18.8	18.7	19.2	19.7
	12H	18.8	19.3	19.3	19.8	20.2	18.3	18.8	18.7	19.2	19.7
8H	4H	18.2	18.8	18.7	19.2	19.7	18.7	19.2	19.1	19.7	20.1
	6H	18.8	19.3	19.3	19.7	20.2	19.0	19.4	19.5	19.9	20.4
	8H	19.1	19.5	19.6	19.9	20.4	19.1	19.5	19.6	20.0	20.5
	12H	19.3	19.6	19.8	20.1	20.6	19.2	19.5	19.7	20.0	20.5
12H	4H	18.3	18.7	18.7	19.2	19.6	18.8	19.3	19.3	19.7	20.2
	6H	18.9	19.3	19.4	19.7	20.2	19.1	19.5	19.6	20.0	20.5
	8H	19.2	19.5	19.7	20.0	20.5	19.3	19.6	19.8	20.1	20.7
Variations with the observer position at spacing:											
S =	1.0H	0.3 / -0.3					0.3 / -0.3				
	1.5H	0.5 / -0.8					0.5 / -0.8				
	2.0H	1.0 / -1.1					1.0 / -1.1				