

iGuzzini

QY45.83: Incasso a 10 celle - Ottica flood - Trasparente / nero



Coefficienti di utilizzazione

R	77	75	73	71	55	53	33	00	DRR
K0.8	67	63	60	58	62	60	59	57	76
1.0	70	66	64	62	65	63	63	60	81
1.5	73	71	69	67	70	68	68	65	87
2.0	76	74	72	71	73	72	71	69	91
2.5	77	76	75	74	75	74	73	71	94
3.0	78	77	76	76	76	75	74	72	97
4.0	79	79	78	77	77	77	76	74	98
5.0	80	79	79	78	78	78	76	74	99

Curva limite di luminanza




Diagramma UGR

Corrected UGR values (at 2900 lm bare lamp luminous flux)											
Reflect.: ceiling/cav walls work pl. Room dim x y		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
		viewed crosswise					viewed endwise				
2H	2H	13.6	14.1	13.8	14.3	14.6	14.4	14.9	14.7	15.2	15.4
	3H	13.6	14.1	13.9	14.3	14.6	14.3	14.8	14.6	15.1	15.4
	4H	13.6	14.0	13.9	14.3	14.6	14.3	14.7	14.6	15.0	15.3
	6H	13.6	14.0	13.9	14.3	14.6	14.2	14.6	14.6	15.0	15.3
	8H	13.5	13.9	13.9	14.3	14.6	14.2	14.6	14.6	14.9	15.3
	12H	13.6	13.9	13.9	14.3	14.6	14.2	14.5	14.5	14.9	15.2
4H	2H	13.5	13.9	13.8	14.2	14.5	14.5	14.9	14.8	15.2	15.5
	3H	13.6	13.9	13.9	14.3	14.6	14.5	14.9	14.9	15.3	15.6
	4H	13.6	13.9	14.0	14.3	14.7	14.5	14.9	14.9	15.3	15.6
	6H	13.6	13.9	14.0	14.3	14.7	14.5	14.8	15.0	15.2	15.6
	8H	13.6	13.9	14.0	14.3	14.7	14.5	14.8	14.9	15.2	15.6
	12H	13.6	13.9	14.1	14.3	14.8	14.5	14.7	14.9	15.1	15.6
8H	4H	13.6	13.9	14.0	14.3	14.7	14.7	15.0	15.2	15.4	15.9
	6H	13.6	13.8	14.1	14.3	14.8	14.8	15.0	15.3	15.5	15.9
	8H	13.6	13.8	14.1	14.3	14.8	14.8	15.0	15.3	15.5	16.0
	12H	13.7	13.8	14.2	14.3	14.9	14.8	14.9	15.3	15.4	16.0
12H	4H	13.5	13.8	14.0	14.2	14.7	14.8	15.1	15.3	15.5	15.9
	6H	13.6	13.8	14.1	14.3	14.8	14.9	15.1	15.4	15.6	16.1
	8H	13.6	13.8	14.1	14.3	14.8	14.9	15.1	15.4	15.6	16.1
Variations with the observer position at spacing:											
S =	1.0H	3.3 / -4.4					2.5 / -3.5				
	1.5H	5.5 / -4.6					4.7 / -3.7				
	2.0H	7.4 / -5.4					6.6 / -4.1				