

Light Emission Distribution Laboratory

Division of Photometry & Electrical Testing Pty. Ltd

Unit 4, 140 George St. Hornsby NSW 2077 Australia

Ph: +61 2 9476 3097 E: sales@ledlab.com.au



Test Report: 200104LCP

Testing of LED Pole-mounted Luminaire Power for AEMO's NEM Load Table and other tests on optical systems

for Twilight Joburg Model No. E026

Type of product: LED Pole-top Luminaire

Prepared for: illuminotecnica, Suite 100, Jones Bay Wharf, 26-32 Pirrama Road, Pyrmont, NSW 2009

Model number: E026

Description: Twilight Joburg - 20.4W Pole-mounted LED luminaire. Features aluminium alloy body, elliptical optic

consisting of an anodized aluminium upper reflector, a polycarbonate lower reflector, a polycarbonate diffuser,

an LED COB powered from a Philips Xitanium LED driver (model number 9290 015 324).

Test objective and Method

Determination of the luminaire supply operating parameters Voltage, Current, Power and Power Factor when tested at nominal test voltages of 250V. By the method of LEDLab Electrical Parameter Determination and AEMO Unmetered_Load_Guideline_v1_0.

Test configuration

The ten luminaires were operated at 25°C ambient temperature in their normal operational orientation at 250VAC, 50Hz, until the monitored luminaire stabilised as defined in IES LM79. Twenty readings were taken ten seconds apart and the average found. The average value is multiplied by the Calibration Correction given in the latest NATA endorsed calibration report then has Voltmeter losses subtracted based on Watt-meter input impedance and test voltage. The other nine luminaires having operated for the same or more time are switched one by one to Watt-meter for their twenty readings.

Client: illuminotecnica, Suite 100, Jones Bay Wharf, 26-32 Pirrama Road, Pyrmont, NSW 2009 contact Robert Woodward

Conclusion

The Average Load (W) is 20.18W at 0.94 Power Factor.

Tested by: David Orwin On 06/01/2020 Authorised Signatory Date: 13/01/2020

Alain Yetendje

Results

Time till stabilisation: 2h

Electrical Measurements

Sample 1 Average Min Max	Supply Voltage (Vrms) 250.057 249.590 250.340	Input Current (Arms) 0.086 0.086 0.086	Input Power (W) 20.286 20.281 20.290	Power Factor 0.940 0.940 0.941
Calibration correction (see Newton 4 th calibration report NC17.36115) Instrument impedance correction (N4) Final value	0.9999 250.03	0.9999 0.00024 0.0860	0.9998 0.0576 20.22	1.0000 0.940
Tillal value	Supply			
Sample 2	Voltage (Vrms)	Input Current (Arms)	(W)	Power Factor
Average	250.277	0.086	20.177	0.937
Min	249.910	0.086	20.174	0.937
Max	250.560	0.086	20.184	0.938
Calibration correction (see Newton 4 th calibration report NC17.36115) Instrument impedance correction (N4)	0.9999	0.9999 0.00024	0.9998 0.0576	1.0000
Final value	250.25	0.0858	20.12	0.937
Sample 3	Supply Voltage	Input Current	•	Power
	(Vrms)	(Arms)	(W)	Factor
Average	250.091	0.086	20.185	0.941
Min Mov	249.810	0.086	20.181	0.941
Max	250.470	0.086	20.190	0.942
Calibration correction (see Newton 4 th calibration report NC17.36115) Instrument impedance correction (N4)	0.9999	0.9999 0.00024	0.9998 0.0576	1.0000
Final value	250.06	0.0855	20.12	0.941

Sample 4 Average Min Max	Supply Voltage (Vrms) 250.270 249.880 250.930	Input Current (Arms) 0.086 0.086 0.086	Input Power (W) 20.256 20.250 20.261	Power Factor 0.942 0.941 0.942
Calibration correction (see Newton 4 th calibration report NC17.36115) Instrument impedance correction (N4) Final value	0.9999 250.24	0.9999 0.00024 0.0857	0.9998 0.0576 20.20	1.0000 0.942
Sample 5 Average Min Max	Supply Voltage (Vrms) 250.275 249.860 250.640	Input Current (Arms) 0.087 0.087 0.087	Input Power (W) 20.412 20.407 20.416	Power Factor 0.941 0.941 0.942
Calibration correction (see Newton 4 th calibration report NC17.36115) Instrument impedance correction (N4) Final value	0.9999	0.9999 0.00024 0.0864	0.9998 0.0576 20.35	1.0000 0.941
Sample 6 Average Min Max	Supply Voltage (Vrms) 250.250 249.950 250.490	Input Current (Arms) 0.086 0.086 0.086	Input Power (W) 20.389 20.386 20.393	Power Factor 0.943 0.943 0.943
Calibration correction (see Newton 4 th calibration report NC17.36115) Instrument impedance correction (N4) Final value	0.9999 250.22	0.9999 0.00024 0.0861	0.9998 0.0576 20.33	1.0000 0.943

LEDLab Test Report: 200104LCP

		EEDEW	o restrictions.	20010 EE
	Supply	Input Current	Input Power	Power
Sample 7	Voltage	(Arms)	(W)	Factor
Avorago	(Vrms) 250.296	0.086	20.196	0.934
Average Min	249.800	0.086	20.196	0.934
Max	250.840	0.086	20.204	0.935
Calibration correction (see Newton 4 th calibration report NC17.36115)	0.9999	0.9999	0.9998	1.0000
Instrument impedance correction (N4)		0.00024	0.0576	
Final value	250.26	0.0861	20.13	0.934
	Supply			_
Sample 8	Voltage	Input Current	•	Power
Campic o	(Vrms)	(Arms)	(W)	Factor
Average	249.938	0.085	20.058	0.941
•				
Min	249.340	0.085	20.053	0.940
Max	250.460	0.085	20.065	0.942
Calibration correction (see Newton 4 th calibration report NC17.36115)	0.9999	0.9999	0.9998	1.0000
Instrument impedance correction (N4)		0.00024	0.0576	
Final value	249.91	0.0850	20.00	0.941
That value	240.01	0.0000	20.00	0.041
	Supply			_
Sample 9	Voltage	Input Current	•	Power
	(Vrms)	(Arms)	(W)	Factor
Average	250.005	0.086	20.325	0.941
Min	249.500	0.086	20.320	0.940
Max	250.410	0.087	20.320	0.941
IVIAX	250.410	0.007	20.331	0.941
Calibration correction (see Newton 4 th calibration report NC17.36115)	0.9999	0.9999	0.9998	1.0000
Instrument impedance correction (N4)		0.00024	0.0576	
Final value	249.97	0.0862	20.26	0.941
	Supply	Input Current	Innut Power	Power
Sample 10	Voltage	•	•	Factor
	(Vrms)	(Arms)	(W)	racioi
Average	250.464	0.086	20.164	0.940
Min	249.920	0.086	20.159	0.939
Max	251.110	0.086	20.169	0.940
out to the state of the state o	0.0000	0.0000	0.0000	1 0000
Calibration correction (see Newton 4 th calibration report NC17.36115)	0.9999	0.9999	0.9998	1.0000
Instrument impedance correction (N4)		0.00024	0.0576	
Final value	250.43	0.0854	20.10	0.940

Electrical operating parameters of 20.4W Twilight Joburg

Comula No	Supply Voltage	Input Current	Input Power	Power Factor	
Sample No.	(Vrms)	(Arms)	(W)		
Sample 1	250.057	0.086	20.225	0.940	
Sample 2	250.246	0.086	20.116	0.937	
Sample 3	250.059	0.085	20.124	0.941	
Sample 4	250.239	0.086	20.195	0.942	
Sample 5	250.244	0.086	20.351	0.941	
Sample 6	250.219	0.086	20.328	0.943	
Sample 7	250.264	0.086	20.135	0.934	
Sample 8	249.906	0.085	19.997	0.941	
Sample 9	249.973	0.086	20.264	0.941	
Sample 10	250.433	0.085	20.102	0.940	
Average	250.16	0.09	20.18	0.94	

Illustration 1: Electrical operating parameters of Twilight Joburg

Uncertainties

At a Confidence Level of 95% with a Coverage Factor of 2

Supply Voltage:± 0.07% Supply Current:± 0.14% Supply Power:± 0.19% Power Factor:± 0.005 Ambient Temperature:± 1°C

Test Equipment Used

Power meter: Newton 4th Power Analyser KinetiQ Model PPA2520 SN 133-00467

Power meter integration time (s): 5

Calibration Report: Ausgrid NC17.36115

Luminaire thermometer: AMA S No. 1086110-0.1deg

General Photographs




Illustration 2: LED driver








Illustration 4: Geartray



Illustration 5: Label