

1.154.977.01 ISK00315/01	iGuzzini	fattore di potenza power factor facteur de puissance Leistungsfaktor vermogensfactor factor de potencia effektfaktor effektfaktor effektfaktor фактор мощности 功率因数	corrente assorbita absorbed current courant absorbé Stromaufnahme stroomopname corriente absorbida absorberet strøm absorbert strøm tillförd ström поглощаемая мощность 电源电流
ART.	λ	A	
N063-N064-MV78-MV79-P586	0.95	0.043	
N065-N066-MV80-MV81-P587	>0.9	0.045	
N067-N068-N069-N070-MV82-MV83-P588	>0.9	0.055	
MV84-MV85-P589	>0.9	0.057	
MV86-MV87-N121-P507 MV88-MV89-N122-P508	0.95	0.060	
MV90-MV91-MV92-MV93-N123-N124-P509	>0.9	0.063	
N093-N094	>0.95	0.146	
MV94-MV95-N125-P510 Q959-Q960-Q961-Q978	>0.9	0.078	
N000-N001-MV96-MV97-N126-N128 P511-P515-N081-N082-N085-N086	>0.9	0.082	
N229-N230-N233-234-N244-N246-P512-P516-N091 N006-N007-N010-N011-N131-N133-N092-N095-N096	>0.9	0.143	
MV98-MV99-N127-P513-N083-N084-N087-N088	>0.9	0.092	
N231-N232-N235-N236-N237-N238-N245-N247 N248-N008-N009-N012-N013-N132-N134-N097 N098-P514-P518-Q965-Q967-Q969-Q980	>0.9	0.154	
N109-N110	>0.9	0.260	
N071-N072-N073-N074-N075-N076 N077-N078-N079-N080-Q985-Q986	>0.9	0.075	
N002-N003-N129	>0.9	0.102	
N004-N005-N130-P517-N089-N090 Q964-Q966-Q968-Q979-Q989-Q990	>0.9	0.112	
N014-N015-N135-N099-N0100 Q974-Q975-Q983-Q993-Q994	>0.9	0.176	
N224-N226-MM97-NMM99-P519-P521 MN01-MN03-N101-N102-N103-N104 N105-N106-N107-N108	>0.9	0.216	
N225-MM98-MN02-P520 N227-MN00-MN04	>0.9	0.230	
N228-N016-N136-P522	>0.98	0.266	
N017-N018	0.95	0.326	
N019-N020	>0.9	0.359	
N021-N022	>0.98	0.316	
N023-N024	>0.98	0.329	
P523-P524-P525	>0,95	0.109	
P526-P527-P528	>0,95	0.134	
P529-P530-P531	>0,95	0.193	
M636-P532-P533	>0.98	0.266	

1.154.977.01 ISK00315/01	iGuzzini	fattore di potenza power factor facteur de puissance Leistungsfaktor vermogensfactor factor de potencia effektfaktor effektfaktor effektfaktor фактор мощности 功率因数	corrente assorbita absorbed current courant absorbé Stromaufnahme stroomopname corriente absorbida absorberet strøm absorbert strøm tillförd ström поглощаемая мощность 电源电流
ART.	λ	A	
N063-N064-MV78-MV79-P586	0.95	0.043	
N065-N066-MV80-MV81-P587	>0.9	0.045	
N067-N068-N069-N070-MV82-MV83-P588	>0.9	0.055	
MV84-MV85-P589	>0.9	0.057	
MV86-MV87-N121-P507 MV88-MV89-N122-P508	0.95	0.060	
MV90-MV91-MV92-MV93-N123-N124-P509	>0.9	0.063	
N093-N094	>0.95	0.146	
MV94-MV95-N125-P510 Q959-Q960-Q961-Q978	>0.9	0.078	
N000-N001-MV96-MV97-N126-N128 P511-P515-N081-N082-N085-N086	>0.9	0.082	
N229-N230-N233-234-N244-N246-P512-P516-N091 N006-N007-N010-N011-N131-N133-N092-N095-N096	>0.9	0.143	
MV98-MV99-N127-P513-N083-N084-N087-N088	>0.9	0.092	
N231-N232-N235-N236-N237-N238-N245-N247 N248-N008-N009-N012-N013-N132-N134-N097 N098-P514-P518-Q965-Q967-Q969-Q980	>0.9	0.154	
N109-N110	>0.9	0.260	
N071-N072-N073-N074-N075-N076 N077-N078-N079-N080-Q985-Q986	>0.9	0.075	
N002-N003-N129	>0.9	0.102	
N004-N005-N130-P517-N089-N090 Q964-Q966-Q968-Q979-Q989-Q990	>0.9	0.112	
N014-N015-N135-N099-N0100 Q974-Q975-Q983-Q993-Q994	>0.9	0.176	
N224-N226-MM97-NMM99-P519-P521 MN01-MN03-N101-N102-N103-N104 N105-N106-N107-N108	>0.9	0.216	
N225-MM98-MN02-P520 N227-MN00-MN04	>0.9	0.230	
N228-N016-N136-P522	>0.98	0.266	
N017-N018	0.95	0.326	
N019-N020	>0.9	0.359	
N021-N022	>0.98	0.316	
N023-N024	>0.98	0.329	
P523-P524-P525	>0,95	0.109	
P526-P527-P528	>0,95	0.134	
P529-P530-P531	>0,95	0.193	
M636-P532-P533	>0.98	0.266	

1.154.977.01 ISK00315/01	iGuzzini	fattore di potenza power factor facteur de puissance Leistungsfaktor vermogensfactor factor de potencia effektfaktor effektfaktor effektfaktor фактор мощности 功率因数	corrente assorbita absorbed current courant absorbé Stromaufnahme stroomopname corriente absorbida absorberet strøm absorbert strøm tillförd ström поглощаемая мощность 电源电流
ART.	λ	A	
N063-N064-MV78-MV79-P586	0.95	0.043	
N065-N066-MV80-MV81-P587	>0.9	0.045	
N067-N068-N069-N070-MV82-MV83-P588	>0.9	0.055	
MV84-MV85-P589	>0.9	0.057	
MV86-MV87-N121-P507 MV88-MV89-N122-P508	0.95	0.060	
MV90-MV91-MV92-MV93-N123-N124-P509	>0.9	0.063	
N093-N094	>0.95	0.146	
MV94-MV95-N125-P510 Q959-Q960-Q961-Q978	>0.9	0.078	
N000-N001-MV96-MV97-N126-N128 P511-P515-N081-N082-N085-N086	>0.9	0.082	
N229-N230-N233-234-N244-N246-P512-P516-N091 N006-N007-N010-N011-N131-N133-N092-N095-N096	>0.9	0.143	
MV98-MV99-N127-P513-N083-N084-N087-N088	>0.9	0.092	
N231-N232-N235-N236-N237-N238-N245-N247 N248-N008-N009-N012-N013-N132-N134-N097 N098-P514-P518-Q965-Q967-Q969-Q980	>0.9	0.154	
N109-N110	>0.9	0.260	
N071-N072-N073-N074-N075-N076 N077-N078-N079-N080-Q985-Q986	>0.9	0.075	
N002-N003-N129	>0.9	0.102	
N004-N005-N130-P517-N089-N090 Q964-Q966-Q968-Q979-Q989-Q990	>0.9	0.112	
N014-N015-N135-N099-N0100 Q974-Q975-Q983-Q993-Q994	>0.9	0.176	
N224-N226-MM97-NMM99-P519-P521 MN01-MN03-N101-N102-N103-N104 N105-N106-N107-N108	>0.9	0.216	
N225-MM98-MN02-P520 N227-MN00-MN04	>0.9	0.230	
N228-N016-N136-P522	>0.98	0.266	
N017-N018	0.95	0.326	
N019-N020	>0.9	0.359	
N021-N022	>0.98	0.316	
N023-N024	>0.98	0.329	
P523-P524-P525	>0,95	0.109	
P526-P527-P528	>0,95	0.134	
P529-P530-P531	>0,95	0.193	
M636-P532-P533	>0.98	0.266	

1.154.544.00
ISO0766/05

SOSTITUZIONE DEL LED
REPLACING THE LED
REPLACEMENT DE LA LED
AUSTAUSCHEN DER LED
VERVANGEN VAN DE LED
REEMPLAZO DEL LED
UDSKIFTNING AF LYSDIODE
BYTE AV LYSDIOD
UTSKIFTING AV DEN LYSEMITTERENDE DIODEN

ЗАМЕНА СИДа
发光二极管替换

I **N.B.:** Per la sostituzione del LED contattare l'azienda iGuzzini.

GB **N.B.:** For information on LED replacement please contact iGuzzini.

F **N.B.:** Pour procéder au remplacement de la LED, adressez-vous à la société iGuzzini.

D **N.B.:** Bezüglich des Austausches der LED kontaktieren Sie bitte die Firma iGuzzini.

NL **N.B.:** Voor het vervangen van de LED neemt u contact op met het bedrijf iGuzzini.

E **NOTA:** Para sustituir el LED llame a la empresa iGuzzini.

DK **N.B.:** For udskiftning af lysdioden, skal man kontakte iGuzzini.

N **N.B.:** For informasjon om skifte av LED, vennligst ta kontakt med iGuzzini.

S **OBS!** För byte av lysdioden, kontakta företaget iGuzzini.

RUS **ПРИМЕЧАНИЕ:** Для замены СИДов обращайтесь в компанию iGuzzini.

CN **注意:** 如需LED更换的信息, 请联系iGuzzini.

I Gruppo di rischio 1, secondo norma **EN 62471: 2008**

GB Risk Group: 1, in compliance with Standard **EN 62471: 2008**

FR Groupe de risque 1, suivant la norme **EN 62471 : 2008**

DE Risikogruppe 1, gemäß Vorschrift **EN 62471: 2008**

NL Risicogroep 1, volgens de norm **EN 62471: 2008**

E Grupo de riesgo 1, según norma **EN 62471: 2008**

DK Faregruppe 1 i henhold til standarden **EN 62471: 2008**

N Risikogruppe 1, i henhold til forskriften **EN 62471: 2008**

S Riskgrupp 1, enligt standard **EN 62471: 2008**

RUS GROUP РИСК 1 В СООТВЕТСТВИИ СО **EN 62471: 2008**

CN 风险组:1
灯具和灯具系统的光生物学安全性符合标准 **EN 62471: 2008**

iGuzzini

1.154.544.00
ISO0766/05

SOSTITUZIONE DEL LED
REPLACING THE LED
REPLACEMENT DE LA LED
AUSTAUSCHEN DER LED
VERVANGEN VAN DE LED
REEMPLAZO DEL LED
UDSKIFTNING AF LYSDIODE
BYTE AV LYSDIOD
UTSKIFTING AV DEN LYSEMITTERENDE DIODEN

ЗАМЕНА СИДа
发光二极管替换

I **N.B.:** Per la sostituzione del LED contattare l'azienda iGuzzini.

GB **N.B.:** For information on LED replacement please contact iGuzzini.

F **N.B.:** Pour procéder au remplacement de la LED, adressez-vous à la société iGuzzini.

D **N.B.:** Bezüglich des Austausches der LED kontaktieren Sie bitte die Firma iGuzzini.

NL **N.B.:** Voor het vervangen van de LED neemt u contact op met het bedrijf iGuzzini.

E **NOTA:** Para sustituir el LED llame a la empresa iGuzzini.

DK **N.B.:** For udskiftning af lysdioden, skal man kontakte iGuzzini.

N **N.B.:** For informasjon om skifte av LED, vennligst ta kontakt med iGuzzini.

S **OBS!** För byte av lysdioden, kontakta företaget iGuzzini.

RUS **ПРИМЕЧАНИЕ:** Для замены СИДов обращайтесь в компанию iGuzzini.

CN **注意:** 如需LED更换的信息, 请联系iGuzzini.

I Gruppo di rischio 1, secondo norma **EN 62471: 2008**

GB Risk Group: 1, in compliance with Standard **EN 62471: 2008**

FR Groupe de risque 1, suivant la norme **EN 62471 : 2008**

DE Risikogruppe 1, gemäß Vorschrift **EN 62471: 2008**

NL Risicogroep 1, volgens de norm **EN 62471: 2008**

E Grupo de riesgo 1, según norma **EN 62471: 2008**

DK Faregruppe 1 i henhold til standarden **EN 62471: 2008**

N Risikogruppe 1, i henhold til forskriften **EN 62471: 2008**

S Riskgrupp 1, enligt standard **EN 62471: 2008**

RUS GROUP РИСК 1 В СООТВЕТСТВИИ СО **EN 62471: 2008**

CN 风险组:1
灯具和灯具系统的光生物学安全性符合标准 **EN 62471: 2008**

iGuzzini

1.154.544.00
ISO0766/05

SOSTITUZIONE DEL LED
REPLACING THE LED
REPLACEMENT DE LA LED
AUSTAUSCHEN DER LED
VERVANGEN VAN DE LED
REEMPLAZO DEL LED
UDSKIFTNING AF LYSDIODE
BYTE AV LYSDIOD
UTSKIFTING AV DEN LYSEMITTERENDE DIODEN

ЗАМЕНА СИДа
发光二极管替换

I **N.B.:** Per la sostituzione del LED contattare l'azienda iGuzzini.

GB **N.B.:** For information on LED replacement please contact iGuzzini.

F **N.B.:** Pour procéder au remplacement de la LED, adressez-vous à la société iGuzzini.

D **N.B.:** Bezüglich des Austausches der LED kontaktieren Sie bitte die Firma iGuzzini.

NL **N.B.:** Voor het vervangen van de LED neemt u contact op met het bedrijf iGuzzini.

E **NOTA:** Para sustituir el LED llame a la empresa iGuzzini.

DK **N.B.:** For udskiftning af lysdioden, skal man kontakte iGuzzini.

N **N.B.:** For informasjon om skifte av LED, vennligst ta kontakt med iGuzzini.

S **OBS!** För byte av lysdioden, kontakta företaget iGuzzini.

RUS **ПРИМЕЧАНИЕ:** Для замены СИДов обращайтесь в компанию iGuzzini.

CN **注意:** 如需LED更换的信息, 请联系iGuzzini.

I Gruppo di rischio 1, secondo norma **EN 62471: 2008**

GB Risk Group: 1, in compliance with Standard **EN 62471: 2008**

FR Groupe de risque 1, suivant la norme **EN 62471 : 2008**

DE Risikogruppe 1, gemäß Vorschrift **EN 62471: 2008**

NL Risicogroep 1, volgens de norm **EN 62471: 2008**

E Grupo de riesgo 1, según norma **EN 62471: 2008**

DK Faregruppe 1 i henhold til standarden **EN 62471: 2008**

N Risikogruppe 1, i henhold til forskriften **EN 62471: 2008**

S Riskgrupp 1, enligt standard **EN 62471: 2008**

RUS GROUP РИСК 1 В СООТВЕТСТВИИ СО **EN 62471: 2008**

CN 风险组:1
灯具和灯具系统的光生物学安全性符合标准 **EN 62471: 2008**

iGuzzini

2.509.216.00
ISO5718/01

استبدال الضوء LED
SOSTITUZIONE DEL LED
REPLACING THE LED
REEMPLAZO DEL LED

تنبيه: لاستبدال الضوء LED اتصل بشركة iGuzzini .

I N.B.: Per la sostituzione del LED contattare l'azienda iGuzzini.

GB N.B.: For information on LED replacement please contact iGuzzini.

E NOTA: Para sustituir el LED llame a la empresa iGuzzini.

فئة الخطر 1 , حسب مقاييس **EN 62471: 2008** .

I Gruppo di rischio 1, secondo norma **EN 62471: 2008**

GB Risk Group: 1, in compliance with Standard **EN 62471: 2008**

E Grupo de riesgo 1, según norma **EN 62471: 2008**

iGuzzini

2.509.216.00
ISO5718/01

استبدال الضوء LED
SOSTITUZIONE DEL LED
REPLACING THE LED
REEMPLAZO DEL LED

تنبيه: لاستبدال الضوء LED اتصل بشركة iGuzzini .

I N.B.: Per la sostituzione del LED contattare l'azienda iGuzzini.

GB N.B.: For information on LED replacement please contact iGuzzini.

E NOTA: Para sustituir el LED llame a la empresa iGuzzini.

فئة الخطر 1 , حسب مقاييس **EN 62471: 2008** .

I Gruppo di rischio 1, secondo norma **EN 62471: 2008**

GB Risk Group: 1, in compliance with Standard **EN 62471: 2008**

E Grupo de riesgo 1, según norma **EN 62471: 2008**

iGuzzini

2.509.216.00
ISO5718/01

استبدال الضوء LED
SOSTITUZIONE DEL LED
REPLACING THE LED
REEMPLAZO DEL LED

تنبيه: لاستبدال الضوء LED اتصل بشركة iGuzzini .

I N.B.: Per la sostituzione del LED contattare l'azienda iGuzzini.

GB N.B.: For information on LED replacement please contact iGuzzini.

E NOTA: Para sustituir el LED llame a la empresa iGuzzini.

فئة الخطر 1 , حسب مقاييس **EN 62471: 2008** .

I Gruppo di rischio 1, secondo norma **EN 62471: 2008**

GB Risk Group: 1, in compliance with Standard **EN 62471: 2008**

E Grupo de riesgo 1, según norma **EN 62471: 2008**

iGuzzini

2.509.216.00
ISO5718/01

استبدال الضوء LED
SOSTITUZIONE DEL LED
REPLACING THE LED
REEMPLAZO DEL LED

تنبيه: لاستبدال الضوء LED اتصل بشركة iGuzzini .

I N.B.: Per la sostituzione del LED contattare l'azienda iGuzzini.

GB N.B.: For information on LED replacement please contact iGuzzini.

E NOTA: Para sustituir el LED llame a la empresa iGuzzini.

فئة الخطر 1 , حسب مقاييس **EN 62471: 2008** .

I Gruppo di rischio 1, secondo norma **EN 62471: 2008**

GB Risk Group: 1, in compliance with Standard **EN 62471: 2008**

E Grupo de riesgo 1, según norma **EN 62471: 2008**

iGuzzini

2.509.216.00
ISO5718/01

استبدال الضوء LED
SOSTITUZIONE DEL LED
REPLACING THE LED
REEMPLAZO DEL LED

تنبيه: لاستبدال الضوء LED اتصل بشركة iGuzzini .

I N.B.: Per la sostituzione del LED contattare l'azienda iGuzzini.

GB N.B.: For information on LED replacement please contact iGuzzini.

E NOTA: Para sustituir el LED llame a la empresa iGuzzini.

فئة الخطر 1 , حسب مقاييس **EN 62471: 2008** .

I Gruppo di rischio 1, secondo norma **EN 62471: 2008**

GB Risk Group: 1, in compliance with Standard **EN 62471: 2008**

E Grupo de riesgo 1, según norma **EN 62471: 2008**

iGuzzini