Laser Blade XS

Design iGuzzini **iGuzzini**

Last information update: December 2024

Product configuration: QI90
QI90: Minimal 2 cells - Medium beam - LED



Product code
QI90: Minimal 2 cells - Medium beam - LED

Technical description
Linear miniaturised recessed luminaire with 2 optical elements for LED lamps - fixed optic. Despite the ultracompact size of the product, the patented technology of the optic system guarantees an efficient luminous flux and a high level of controlled glare visual comfort. Main body with die-cast zamak radiant surface, minimal (frameless) version for mounting flush with the ceiling. For recessed installation in a false ceiling a specific adapter is required that is available with a separate item code. Metallised, thermoplastic, high definition Opti Beam reflector, integrated in a set-back position in the anti-glare screen. Ballast not included, available with separate code.

Installation
The luminaire is recessed in the specific adapter (QJ87) by means of a steel wire spring, previously installed on the ceiling that can be 12.5 / 15 / 20 mm thick. A special protective sheath allows finishing operations on the plasterboard to be simplified and speeded up.



Colour
White (01) | Black (04) | Gold (14)* | Burnished chrome (E6)*

Weight (Kg)
0.08

* Colours on request

Mounting
wall recessed|ceiling recessed

Wiring
Constant current ballasts to be ordered separately: ON-OFF - code no. MXF9 (min 1 / max 4); dimmable DALI - code no. BZM4 (min 1 / max 10) - check the instruction sheet for the lengths and compatible cross-sections of the cables to be used.

Notes
The special steel wire spring provided is required to facilitate the eventual extraction of the recessed body once it has been inserted.

Complies with EN60598-1 and pertinent regulations

IP20

Technical data

lm system:	274	CRI (minimum):	90
W system:	4	Colour temperature [K]:	2700
lm source:	360	MacAdam Step:	2
W source:	4	Life Time LED 1:	> 50,000h - L80 - B10 (Ta 25°C)
Luminous efficiency (lm/W, real value):	68.4	Lamp code:	LED
lm in emergency mode:	-	Number of lamps for optical assembly:	1
Total light flux at or above an angle of 90° [Lm]:	0	ZVEI Code:	LED
Light Output Ratio (L.O.R.) [%]:	76	Number of optical assemblies:	1
Beam angle [°]:	24°	LED current [mA]:	700

Polar



CIE
nL 0.76
100-100-100-100-76
UGR <10-<10
DIN
A.61
UTE
0.76A+0.00T
F"1=998
F"1+F"2=999
F"1+F"2+F"3=1000
CIBSE
LG3 L<1500 cd/m² at 65°
UGR<10 | L<1500 cd/mq @65°

Lux

h	d	Em	Emax
1	0.4	1079	1263
2	0.9	270	316
3	1.3	120	140
4	1.7	67	79

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	69	65	63	61	65	62	62	60	78
1.0	72	69	66	65	68	66	65	63	83
1.5	75	73	71	69	72	70	70	67	89
2.0	77	76	74	73	75	73	73	71	93
2.5	79	78	77	76	77	76	75	73	96
3.0	80	79	78	78	78	77	76	74	98
4.0	81	80	80	79	79	78	77	75	99
5.0	81	81	80	80	80	79	78	76	100

Luminance curve limit



UGR diagram

Corrected UGR values (at 360 lm bare lamp luminous flux)

Riflect.: ceil/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim				viewed crosswise					viewed endwise		
x	y										
2H	2H	4.1	6.2	4.5	6.5	6.9	4.1	6.2	4.5	6.5	6.9
	3H	4.0	5.6	4.4	5.9	6.2	4.0	5.6	4.3	5.9	6.2
	4H	4.0	5.3	4.3	5.6	5.9	3.9	5.2	4.3	5.6	5.9
	6H	4.0	5.0	4.3	5.3	5.7	3.9	4.9	4.3	5.2	5.6
	8H	4.0	5.0	4.3	5.3	5.7	3.8	4.8	4.2	5.2	5.6
	12H	4.0	5.0	4.4	5.4	5.7	3.8	4.8	4.2	5.2	5.5
4H	2H	3.9	5.2	4.3	5.6	5.9	4.0	5.3	4.3	5.6	5.9
	3H	3.8	4.8	4.2	5.2	5.6	3.8	4.8	4.2	5.2	5.6
	4H	3.7	4.7	4.1	5.1	5.5	3.7	4.7	4.1	5.1	5.5
	6H	3.4	5.1	3.9	5.6	6.0	3.4	5.1	3.9	5.5	6.0
	8H	3.4	5.3	3.9	5.7	6.2	3.3	5.1	3.7	5.6	6.1
	12H	3.4	5.4	3.9	5.9	6.4	3.2	5.1	3.7	5.6	6.1
8H	4H	3.3	5.1	3.7	5.6	6.1	3.4	5.3	3.9	5.7	6.2
	6H	3.3	5.1	3.8	5.5	6.1	3.4	5.1	3.9	5.6	6.1
	8H	3.4	4.9	3.9	5.4	6.0	3.4	4.9	3.9	5.4	6.0
	12H	3.8	4.8	4.3	5.3	5.8	3.6	4.6	4.1	5.1	5.6
12H	4H	3.2	5.1	3.7	5.6	6.1	3.4	5.4	3.9	5.9	6.4
	6H	3.3	4.8	3.8	5.3	5.9	3.5	5.1	4.0	5.6	6.1
	8H	3.6	4.6	4.1	5.1	5.6	3.8	4.8	4.3	5.3	5.8

Variations with the observer position at spacing:

S =			
	1.0H	6.3 / -5.9	6.3 / -5.9
	1.5H	9.0 / -6.0	9.0 / -6.0
	2.0H	11.0 / -6.1	11.0 / -6.1