





**Polar**



**Isolux**



**Diagrama UGR**

Corrected UGR values (at 3050 lm bare lamp luminous flux)																
Reflect.:		viewed crosswise					viewed endwise									
ceil/cav	walls	work pl.	Room dim	x	y	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30	
2H	2H	13.7	15.6	14.1	15.9	16.3	13.7	15.6	14.1	15.9	16.3	13.8	15.3	14.2	15.6	16.0
	3H	14.0	15.5	14.4	15.8	16.2	13.8	15.3	14.2	15.6	16.0	13.8	15.1	14.2	15.4	15.8
	4H	14.1	15.3	14.5	15.7	16.0	13.8	14.8	14.2	15.2	15.5	13.8	14.8	14.2	15.2	15.5
	6H	14.1	15.1	14.4	15.4	15.8	13.8	14.8	14.2	15.1	15.5	13.8	14.8	14.2	15.1	15.5
	8H	14.0	15.0	14.4	15.4	15.7	13.8	14.8	14.2	15.1	15.5	13.8	14.8	14.2	15.1	15.5
	12H	14.0	14.9	14.4	15.3	15.7	13.7	14.7	14.1	15.1	15.4	13.7	14.7	14.1	15.1	15.4
4H	2H	13.8	15.1	14.2	15.4	15.8	14.1	15.3	14.5	15.7	16.0	14.3	15.3	14.7	15.6	16.0
	3H	14.3	15.3	14.7	15.6	16.0	14.3	15.3	14.7	15.6	16.0	14.3	15.2	14.7	15.6	16.0
	4H	14.3	15.2	14.7	15.6	16.0	14.3	15.2	14.7	15.6	16.0	14.1	15.6	14.5	16.0	16.5
	6H	14.0	15.6	14.5	16.0	16.5	13.9	15.7	14.4	16.1	16.6	13.9	15.7	14.4	16.1	16.6
	8H	13.9	15.6	14.4	16.1	16.6	13.8	15.6	14.3	16.1	16.6	13.8	15.6	14.3	16.1	16.6
	12H	13.8	15.6	14.3	16.1	16.6	13.8	15.6	14.3	16.1	16.6	13.9	15.6	14.4	16.1	16.6
8H	4H	13.9	15.7	14.4	16.1	16.6	13.8	15.5	14.4	16.0	16.5	13.8	15.3	14.4	15.8	16.3
	6H	13.9	15.5	14.4	16.0	16.5	13.9	15.0	14.5	15.5	16.0	13.9	15.0	14.5	15.5	16.0
	8H	13.8	15.3	14.4	15.8	16.3	13.8	15.0	14.5	15.5	16.0	13.8	15.3	14.4	15.8	16.3
	12H	13.9	15.0	14.5	15.5	16.0	13.8	15.6	14.3	16.1	16.6	13.8	15.6	14.3	16.1	16.6
12H	4H	13.8	15.6	14.3	16.1	16.6	13.8	15.6	14.3	16.1	16.6	13.8	15.3	14.3	15.8	16.3
	6H	13.8	15.3	14.4	15.8	16.3	13.9	15.0	14.5	15.5	16.0	13.9	15.0	14.5	15.5	16.0
	8H	13.9	15.0	14.5	15.5	16.0	13.9	15.0	14.5	15.5	16.0	13.9	15.0	14.5	15.5	16.0
Variations with the observer position at spacing:																
S =	1.0H	2.0 / -1.7					2.0 / -1.7									
	1.5H	3.9 / -2.6					3.9 / -2.6									
	2.0H	5.7 / -3.5					5.7 / -3.5									